

Southeys Key tips
for workers
working around
gas carriers, input
to SOP 23/2/2021
from the Health
and Safety
meeting Jan 2021

- bring pressures down around strategic gas mains
- on the plans, different colours mean different things
- the codes mean different things, for example ST is steel
- if the pipe is corroded you need to evacuate, first get out of the way, then use the emergency stop to turn the hydro off, try not to leave the hose/arm extended over the area if possible
- the minimum width is so you can see what your excavating
- ask to see permits, for example a permit is only valid for 14 days the plans however are valid for 28 days, operators should ask to see both

(this is to sit alongside the formal SOP and Vector Safety Alert, it is from the worker meeting, questions please email steph@southeysgroup.com)

